



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 17/10/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-6A	B/C OLR ACTED	RESET DONE	22:55:00	23:10:00	
2	OHP	BRC ON CO-31	B/C NOT RUNNING CHECKED AND FOUND OLR ACTED	RESET DONE	00:50:00	01:10:00	
3	OHP	BRC ON CO-32	REPORTED LT NOT TAKING PLACE CHECKED AND FOUND BREAK MCB TRIPPED	MCB MADE ON THAN OK	00:55:00	01:20:00	
4	CHP	TT ON CC-26	NOT MOVING FOUND MPCB TRIP	RESET DONE	22:50:00	23:00:00	
5	CHP	CC-38 SCR-6	LT NOT TAKING PLACE DRIVE TRIP (2TIMES)	RESET DONE	01:55:00 02:25:00	02:10:00 02:40:00	
6	CHP	CC-36 S-2	REPORTED NO POWER FOUND HT CABLE OLD JOINT OPENED	COUPLER ,SLIPRING SIDE OPENED CABLE LOOP GIVEN	03:50:00	04:45:00	
7	CHP	CC-54	TRIPPED ON OLR (8TIMES)	RESET DONE	04:30:00	06:00:00	DUE TO MATERIAL OVER LOAD
8	CHP	CC-28 F/G	MPCB TRIPPED	MADE ON	05:10:00	05:15:00	
9	WT	OP-10	NOT MOVING CHECKED AND FOUND R PHASE NOT COMING IN PUSHER	ISOLATAR ON/OFF THAN OK (COL-NO 21)	22:30:00	23:10:00	
10	WT	OP-10	NOT MOVING DRIVE -6 TRIPPED	POWER RECYCLED THAN OK	23:45:00	23:50:00	
11	WT	OT-4	HYDRAULIC PUMP MOTOR TRIPPED FAULT UNDER CURRENT(OL)	RESET DONE	04:45:00	04:55:00	