



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/12/2025

Area: IOSA

Equipment	Job
OC-19A	HEAD END LIGHTING CIRCUIT DEFECTS RECTIFIED. SUFFICIENT LIGHTING ARRANGED. DEFECTIVE LIGHT FITTINGS REMOVED AND SHIFTED TO ELECTRICAL SHED.
OC-27A	GALLERY LIGHTING CIRCUIT DEFECTS RECTIFICATION IS IN PROGRESS.
OC-9A	GALLERY AND JUNCTION HOUSE LIGHTING CIRCUIT DEFECTS RECTIFICATION IS IN PROGRESS.
OC-11A	GALLERY AND JUNCTION HOUSE LIGHTING CIRCUIT DEFECTS RECTIFICATION IN PROGRESS
WOBR-FLS	TRIAL RUN TAKEN AND CHECKED ALL FUNCTIONS.
BLENDER RECLAIMER	BUCKET WHEEL -2 ZSS PROBE ADJUSTMENT DONE.
OC-18A	PPM DONE ON MOTOR AND FIELD DEVICES.