



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/05/2025

Incharge(s): K SANKARA RAO

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|------------------------------------|-------------------------|----------|----------|---------------------------------------|
| 1 | OHP | CO 35 | OLR ACTED | RESET | 01:30:00 | 01:40:00 | |
| 2 | OHP | CO 26 | OLR ACTED | RESET | 03:00:00 | 03:10:00 | |
| 3 | OHP | TBS ON CO 20 | LT NOT TAKING PLACE PCRD O/T ACTED | RELEASED | 02:00:00 | 02:15:00 | |
| 4 | OHP | CO 11 (C) DRIVE | MPCB TRIPPED | MADE ON | 05:00:00 | 05:10:00 | |
| 5 | OHP | CO 32 | ZS PROBE DAMAGED | PROBE REPLACED | 03:00:00 | 03:15:00 | DUO TO BELT JUMPING IN FORMED TO MECH |
| 6 | CHP | CC 107 | BRS ACTED | SENSORS CLEANED THAN OK | 01:20:00 | 01:30:00 | |
| 7 | WT | OP 5 | D5 OLR ACTED | RESET | 00:40:00 | 00:50:00 | |