



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 07/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-6A	Luffing not working	Oil level low.	15:30:00	15:40:00	Informed to operation
2	OHP	CO-29	Reported tripped	Reset done.	16:40:00 21:45:00	16:50:00 21:50:00	
3	CHP	CC-28	Reported tripped	OLR acted.Reset done(2times).	19:30:00 20:00:00	19:40:00 20:10:00	
4	CHP	CC19	Reported tripped	OLR acted.Reset done	20:20:00	20:30:00	
5	CHP	Cc-51	Reported tripped	MPD tripped.Reset done(3 times)	19:25:00 21:00:00 21:20:00	19:30:00 21:05:00 21:24:00	
6	CHP	Cc32 R-1	Luffing down not working	D2 contactor stuck up.Made free and tested okay	18:17:00	19:05:00	
7	CHP	Cc107	Reported tripped	OLR acted.Reset done	19:10:00	19:15:00	
8	CHP	Cc 125	Reported tripped	OLR acted.Reset done	19:25:00	19:30:00	
9	CHP	Cc34 SCR-2	LT not working	Track jamming.	21:10:00	21:25:00	Informed to operation
10	WT	OC-1A	Reported ZSS acting	Checked and found jamming	14:30:00	14:45:00	Informed to operation
11	IOSA	WOBR(FLS)	Reported B/W not rotating	Stone stuck up.	20:40:00	20:50:00	Informed to operation