



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/05/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO10 (C) DRIVE	MPCB TRIPPED	MADE ON	14:30:00	14:40:00	
2	OHP	BRC ON CO28	B/W 1 POWER MCCB TRIPPED	MADE ON	15:40:00	15:55:00	
3	OHP	CO 35	OLR ACTED	RESET	16:50:00	17:00:00	
4	OHP	CR 3	MOTER PROTECTION RELAY ACTED	RESET	17:30:00	17:40:00	
5	OHP	CO25	OLR ACTED	RESET	20:00:00 20:30:00	20:15:00 20:45:00	
6	OHP	CR1A	STOPPING ON ZS PROBE WIRE GOT CUT	JOINT DONE	17:30:00	17:45:00	
7	CHP	CC54	OLR ACTED	RESET	19:40:00	19:45:00	DUE TO JAMMING, TRIP 5TIMES
8	CHP	cc 104 scr 9	B/C not running,signal problem	LT done than ok	16:50:00	17:00:00	
9	CHP	CC 43	chute sensor acted,jamming	reset it done	20:50:00	21:00:00	
10	WT	OP3	DRIVE 3 OLR ACTED	RESET	17:30:00	17:45:00	
11	WT	OT2	DRIVE PGF FAULT	RESET	20:30:00	20:45:00	