



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/06/2025

Incharge(s): Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR acted	reset done	07:45:00	07:55:00	
2	OHP	CO 87	DMPR shows in overload (2 times)	reset done	09:00:00	09:35:00	
3	OHP	CO 5	BRS in bypass condition	Kept in circuit after operation clearance	07:30:00	07:45:00	
4	CHP	CC 44	BRS to be bypassed as per operation request	Bypass done	08:50:00	09:00:00	In IO rack
5	CHP	CC 125	OLR acted (3 times)	reset done	10:30:00	10:40:00	
6	CHP	CC 44	OLR acted	reset done	10:50:00	10:55:00	
7	CHP	CC 34	Material selection to be bypassed	Bypass done	12:36:00	12:38:00	
8	CHP	CC 54	Tripped in overload	reset done	12:10:00	12:25:00	
9	WT	OP 8	Motor 4 tripped	reset done	12:20:00	12:30:00	