



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/06/2025

Shift: C

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO6A	LT DRIVE TRIP(2TIMES)	RESET	22:50:00	01:50:00	
2	OHP	CO 35	OLR ACTED (3TIMES)	RESET	23:35:00	01:20:00	
3	OHP	CO 29	OLR ACTED(2TEMES)	RESET	02:45:00	03:15:00	
4	OHP	BRC ON CO 8A	B/W 2 ZS PROBLEM	ZS BY PASSED	01:35:00	01:50:00	
5	OHP	BRC ONCO 8A	B/C OLR ACTED	RESET	03:00:00	03:20:00	
6	OHP	BRC ON CO30	B/C OLR ACTED	RESET	03:35:00	03:45:00	DUE TO MATERIAL JAMMING
7	OHP	BRC ON CO 34	B/W 1 STOPPING ON ZS	WRONG COMPLAINT	03:35:00	04:00:00	
8	OHP	TBS ON CO20	LT NOT TAKING PLACE PCRED O/T ACTED	RELEASED	05:00:00	05:20:00	
9	OHP	RSCO 6A	OLR ACTED	RESET	00:25:00	00:40:00	
10	OHP	CO 18	OLR ACTED	RESET	23:50:00	00:00:00	
11	CHP	CC 40 SCR 6	FAN HEALTHY BIT NOT COMING	MPCB NO CONTACT TIGHT THAN OK	22:40:00	22:50:00	
12	CHP	CC 34 SCR 2	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	23:00:00	23:10:00	
13	CHP	CC 39 SCR 7	B/C NOT RUNNING MPD TRIP	RESET	01:05:00	01:15:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/06/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC33 SCR 4	B/C NOT RUNNING	WORONG COMPLAINT	02:50:00	03:00:00	
15	CHP	CC32 SCR 5	LT NOT TAKING PLACE M2 AND M3 MPCB TRIP	MADE ON	03:10:00	03:20:00	
16	CHP	CC 131	OLR ACTED (5TIMES)	RESET	02:05:00	05:15:00	
17	CHP	CC 54	OLR ACTED(5TIMES)	RESET	23:50:00	01:55:00	
18	WT	OC1A	OLR ACTED	RESET	01:10:00	01:15:00	
19	WT	CP 1	DRIVE CONTROL TRIP COL NO 11	RESER	05:45:00	06:00:00	