



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/09/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-21	L/BC ZSS PROBE DAMAGED	ZSS PROBE REPLACED THAN OK	16:00:00	16:30:00	
2	OHP	TBS ON CO-24	L/LUFF NOT WORKING CHECKED AND FOUND BREAK PROBLEM	INFORMED TO MECHANICAL	16:20:00	16:40:00	
3	OHP	WOBR ON CO-29	REPORTED ALL DRIVES ARE NOT RUNNING CHECKED AND FOUND DOWN LIMIT ACTED	LIMIT BYPASSED THAN BOOM KEPT IN CORRECT POSITION THAN BYPASS REMOVED	20:00:00	20:15:00	
4	OHP	CO-26	OLR ACTED	RESET DONE THAN OK	20:30:00	20:40:00	
5	OHP	CO-35	OLR ACTED	RESET DONE	20:50:00	21:00:00	
6	OHP	CO-13A	REPORTED BRS NOT RESET	SENSOR CLEAN THAN BRS RESET DONE OK	20:55:00	21:10:00	
7	OHP	CC-39 S-1	REPORTED LT NOT TAKING PLACE PCRD U/T LIMIT ACTED	LIMIT RELEASED AND PCRD CABLE PROPER LAYING WAS DONE	17:10:00	17:30:00	
8	CHP	CC-39 S-1	LT DRIVE TRIP	RESET DONE THAN OK	14:30:00	14:40:00	
9	CHP	CC-39 S-1	LT DRIVE TRIP	RESET DONE	17:30:00	17:45:00	
10	CHP	CC-40 SCR-3	LT DRIVE TRIP OVN FAULT	RESET DONE THAN OK	20:40:00	20:50:00	
11	WT	AF-1	DRIVE TRIP (EARTH GROUND FAULT)CHECKED AND FOUND CHAI9N DAMAGED	INFORMED TO MECHANICAL THAN DRIVE RESET DONE	18:15:00	18:30:00	