



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/06/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 6A	LT not working due to PCRD overtension	tension released , then ok	06:50:00	07:05:00	
2	OHP	V F 2A	Drive tripped due to coal side motor burn	Motor changed	07:00:00	14:00:00	Informed operation for cleaning
3	OHP	TT 2 on CO 21	Position indication not coming	Fuse TB loose , connected properly	07:25:00	07:35:00	
4	OHP	CO 77	Overload acted	reset done	13:15:00	13:20:00	
5	OHP	CR 1A	Stopping on high vibration	Vibration showing 50 continuously	13:00:00	13:30:00	Informed to instrumentation
6	CHP	CC 39 , SCR 7	BW not running	Fault reset done in operator cabin	07:10:00	07:20:00	
7	CHP	CC 32 , SCR 5	BC not running	Fault reset done in operator cabin	07:45:00	07:50:00	
8	CHP	CC 39 , SCR 7	LT not working due to PCRD overtension acted	tension released , then ok	10:55:00	11:10:00	
9	CHP	CC 33	Tripped in overload	reset	12:05:00 12:40:00	12:15:00 12:45:00	
10	CHP	CC 32	Tripped in overload	reset	12:15:00	12:20:00	
11	CHP	CC 201	Tripped in overload	reset done	12:25:00	12:30:00	
12	CHP	CC 54	Tripped in overload	reset done	09:15:00	09:20:00	
13	CHP	CC 131	Tripped in overload	reset done	13:40:00	13:45:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/06/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OP 7	Not moving , individual breaker tripped	made on	10:00:00	10:15:00	
15	WT	CP 2 and CP 4	Communication problem	PLC recycled at cabin	11:20:00	11:40:00	
16	WT	7A / 5A material selection	5a kept in dolo	At LC 1	11:00:00	11:10:00	