



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/11/2025

Area: OHP

Equipment	Job
co-1a pullchord from brs area to t/e	checked , spare core used and restored pull chord in circuit.
co-15 ; tt-2	ppm is done at motor and panel sides
bpc-1	motor and panel ppm is done
spare magnet	spare magnet near cbms of co-6a is checked and tested, found ok.
ars feeder of 1-14lc20	voltas breaker was not making on, changed with spare breaker and made on, found supply not available still at ARS, checking is under progress.