



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/06/2025

Shift: B

Incharge(s): Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT-2 SIGNAL ON CO-21	MISSED BECOUSE OF CHUT JAM .. BYPASSED ON OPR REQUEST	AGAIN KEPT IN CKT	20:40:00	20:50:00	
2	OHP	CO34 BRC	OIL TEMP ANALOG SIGNAL PROBLEM	BYPASSED	17:15:00	18:00:00	
3	OHP	CO-59 AND CO21	BRS PUT IN CKT REQ	KEPT IN CKT	17:30:00	18:15:00	
4	OHP	CO-32 BRC	BC STOPPING ... BELT PIECE WOUNDED IN PULLY	INFORMED OPR	20:40:00	21:00:00	
5	OHP	CO-35	OLR ACTED	RESET DONE	19:25:00	19:30:00	
6	OHP	CO-49	PULL CORD EARTH FAULT	BYPASSED	21:40:00	21:50:00	
7	OHP	CO-6A WOBR	LT DRIVE TRIPPING IN EARTH FAULT AFTER RUNNING FOR SOME TIME	CHECKING GOING ON	21:30:00	22:00:00	
8	CHP	CC-44	TRIPPED ON OLR	RESET DONE	15:10:00	15:20:00	
9	CHP	CC-40 SCR-6	SLEW NOT WORKING	30 DEGREE LIMIT ACTED ... TEMPORARILY BYPASSED AND AGAIN KET IN CIRCUIT AND TESTED	19:00:00	19:20:00	
10	CHP	CC-32 SCR-5	LT NOT WORKING M2 AND M3 TRIPPED	RESET DONE	19:40:00	20:00:00	
11	CHP	CC-32 SCR-5	LUFF NOT WORKING	FILTER CLOG PROBLEM BYPASSED ON OPERATION REQUEST AND INFORMED MECH	20:00:00	20:20:00	AFTER FILTER CHANGING KEPT IN CKT



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/06/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-54	TRIPPED ON OLR	RESET DONE	17:45:00 19:30:00 20:55:00	17:50:00 19:35:00 21:00:00	
13	CHP	CC-131	TRIPPED ON OLR	RESET DONE	20:55:00	21:00:00	
14	CHP	CP-2	COMMUNICATION PROBLEM	RECYCLED	19:50:00 21:35:00	19:55:00 21:40:00	
15	WT	OT-5 STREEM	SHOWING RED	POWER RECYCLED	16:15:00	16:25:00	
16	WT	OT-3	DRIVE 1 TRIPPED ON ENCODER FAULT	RESET	20:00:00	20:05:00	