



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 21/01/2026

Area: OHP

| Equipment                        | Job   |
|----------------------------------|---|
| locp-2 crushers                  | For CR-1 and CR-2 ht fuse fail contact is taken and taken to io rack using a spare core. to be interlocked. |
| co-50,53,56                      | cjd ppm is done ; co-50 zss cage is replaced.   |
| daybins-1 bunker level sensors   | ppm is done   |
| co-33a,35a,37a                   | safety devices ppm is done  |
| cr-2 panel                       | contactor checking is done using coil controller.   |
| 1-14lc3 incomer 1 voltas breaker | maintenance is done and breaker ON mechanism rectified.   |
| co-5,8,11,3a ; co-8a             | motor and panel side ppm is done  |