



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/07/2025

Area: CHP

Equipment	Job
SCR 3,6	Communication Healthy indication out put programmed
CC 117	Burnt motor coupling removed and sent to ERS
SCR 10	One 200W LED replaced and lighting ckt problems rectified
CC 112 to 33	HT coupler space heater inspection was done
CC 39,36,SCR 7 ,S1	PPM was done
CC 36	Drive chute sensor modification done
SCR 7,S 1	Interchanged the yard machines