



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 4A	olr acted	reset	07:07:00	07:12:00	
2	OHP	BRC on Co 33M	B/C not running,emergency Pb acted	PB released	09:55:00	10:05:00	
3	OHP	WOBR on Co26	slew not working,drive tripped	reset	10:35:00	10:50:00	
4	OHP	BRC on Co 30	b/c not running,OLr acted	reset	07:55:00	08:10:00	
5	OHP	CO 77	olr acted	reset	13:05:00	13:15:00	
6	CHP	CC 38 SCR6	LT not working	wrong complaint,all ok	06:15:00	06:25:00	
7	CHP	cc 38 scr 6	LT not working,drive tripped in f30003 fault	reset	07:40:00	07:52:00	
8	CHP	cc 39 scr2	Lt not working,Ot acted	OT released	07:20:00	07:30:00	
9	CHP	CC 107	olr acted	reset	08:55:00	09:00:00	
10	CHP	CC 51	olr acted	reset	08:15:00	12:30:00	4 times
11	CHP	CC 51	MPD tripped 12 times	reset	08:10:00	13:40:00	
12	WT	OT1	D2 tripped in pgf1 fault	reset	09:40:00	09:45:00	
13	IOSA	brc	LT not working,thruster brake MPCB tripped	made on	10:30:00	10:45:00	