



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 08/10/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported Tripped	OLR acted.Reset done	06:38:00	06:44:00	
2	OHP	BRC on CO-30	Reported slewing not working	OLR acted.Reset done	08:50:00	09:15:00	
3	CHP	CC-33 SCR-5	LT drive problem pending from C-shift	Drive changed parameterization done and tested okay	06:00:00	09:20:00	
4	CHP	CC-28	Reported tripped	OLR acted.Reset done	11:00:00	11:10:00	
5	CHP	CC-18	Reported ZSS acting	Cage stuck up.Made free and tested okay	12:30:00	12:45:00	
6	CHP	CC-51	reported tripped	MPD tripped.Reset done	07:25:00 10:10:00 10:40:00	07:30:00 10:15:00 10:45:00	
7	WT	OT-4	Reported not rotating	Checked and found hydraulic pump is not on.Made on and tested okay	06:30:00	07:00:00	
8	WT	OT-1	Reported tripped	Drive 1 tripped.Reset done	09:30:00 13:55:00	09:35:00 14:00:00	
9	WT	CT-1	Initial not coming	Limit adjusted but jamming found	10:35:00	10:45:00	Informed to operation