



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 28	BW not running	mechanical problem	18:35:00	18:45:00	
2	OHP	BRC on co 32	pump not running,oil cooler motor problem	bypass and given clearance,contactor problem	20:50:00	21:10:00	checking going on
3	CHP	CC 34 scr1	luff not working,olr acted	reset	17:20:00	17:30:00	
4	CHP	CC 34 SCr1	bw 1 not running,olr acted	reset	17:30:00	17:35:00	
5	CHP	CC 39 SCR6	b/c not running,	yard running interlock problem	20:30:00	20:40:00	operator mistake