



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/10/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC-34	CT NOT WORKING	SS WAS IN LOCAL ... KEPT IN REMOTE	19:55:00	20:05:00	
2	OHP	BSC ON CO 32	LT NOT WORKING	SKEW ACTED ... ADJUSTED WITH MECHANICAL	18:00:00	18:10:00	
3	OHP	CO -67	TRIPPED ON OLR	RESET DONE	16:00:00	16:10:00	
4	OHP	TT-4 ON BPC-2	INDICATION NOT COMING	PROB WIRE CUT ... JOINT DONE	16:15:00	16:30:00	
5	OHP	DB-1	TRIPPED ON OLR	RESET DONE	20:00:00	20:10:00	
6	CHP	CC-32 R-1	REPORTED B/C NOT RUNNING CHECKED AND FOUND NO PROBLEM	WRONG COMPLAINT	15:45:00	16:00:00	
7	CHP	CC-39	OLR ACTED	RESET DONE	18:05:00	18:10:00	
8	CHP	CC-108	OLR ACTED	RESET DONE	21:00:00	21:05:00	
9	CHP	CC-112 SCR-8	REPORTED B/C NOT RUNNING FOUND NO PROBLEM	WRONG COMPLAINT	16:20:00	16:30:00	
10	CHP	CC-112 SCR-8	B/C NOT RUNNING	ZSS CAGE STUCK ... MADE FREE	18:50:00	19:00:00	
11	CHP	cc-38 scr-6	LT NOT WORKING	MPCB-2 TRIPPED ... RESET DONE	21:30:00	21:40:00	
12	WT	OT-4	D-2 TRIPPED IN PGF FAULT	RESET DONE	18:00:00	18:15:00	