



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 02/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 34	BW not running due to charge pressure alarm acted	reset done	16:45:00	17:00:00	
2	OHP	CO 84	OLR acted	reset done	16:40:00	16:50:00	
3	OHP	CO 26	OLR acted	reset done	18:25:00 18:55:00	18:35:00 19:05:00	
4	OHP	BRC on CO 30	BC direction reverse on operation request	again kept in normal direction and tested	17:45:00	20:00:00	
5	OHP	CO 33M	Chute sensor malfunctioning	module problem , bypassed	16:15:00	16:30:00	
6	CHP	CC 40	Not healthy , control off	control made on	14:30:00	14:40:00	
7	CHP	CC 111 , S 3	Luff not working	Mccb tripped, made on	17:45:00	18:10:00	
8	CHP	CC 32, SCR 5	LT not working due to OT acted	released, then ok	17:45:00	18:00:00	
9	CHP	CC 31	OLR acted	reset done	21:15:00	21:20:00	
10	CHP	CC 54	OLR acted	reset done	18:45:00	18:50:00	
11	CHP	CC 53	TT position on RG 2 not coming	Checked, physically okay. Position bit bypassed in IO rack	19:00:00	19:30:00	
12	WT	CO 3	Belt drive OLR acted	reset done	20:20:00	20:25:00	