



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 23/06/2025

Area: CHP

| Equipment          | Job   |
|--------------------|---|
| Coal complex,LC 17 | Rooms cleaning done                                     |
| SCR 10             | 5 nos tube fixtures replaced in MCC room                |
| SCR 4              | PCRD rev command relay replaced and trial run was taken |
| SCR 1              | Boom position sensor kept in ckt                        |
| CC 201 to 206      | PPM was done  |