



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 28/05/2025

Area: CHP

Equipment	Job
CM 19,CM 18	Rooms cleaning done
SCR 2	CD to IO rack control cable got damaged at cabin,rectified and tested slew drive
SCR 5	PCRD OLR replaced
CC 202,131,53	New lamp fixtures provided and lighting rectification done
CC 215,216,217,218,220,221,222	PPM was done
CC 49	BRS Receiver replaced and kept in ckt
CC 31.33,125,108	Running inspection was done