



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/09/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-10A	OLR	ACTED	14:40:00	14:55:00	
2	OHP	VF-16A	OLR ACTED	RESET DONE	17:15:00	17:30:00	
3	OHP	CO-58	OLR ACTED	RESET DONE	18:05:00	18:20:00	
4	OHP	CO-3A	BRS NOT RESETTING	WIRE LOOSE .. FIXED	20:00:00	20:15:00	
5	OHP	VF-16A	TRIPPING	CABLE CUT ... JOINT DONE	18:00:00	18:40:00	
6	CHP	CC-29	TRIPPED ON OLR (THREE TIMES)	RESET DONE	16:00:00	16:40:00	
7	CHP	CC-31 SCR-4	OIL LOW AND TEMP HIGH OF SLEW	RESET DONE AFTER OIL TOPUP	19:30:00	20:00:00	
8	CHP	CC-37 SCR-7	LT NOT WORKING .. M2,3,6 TRIPPED AND PCRD OT	RESET .. OT RELEASED	21:00:00	21:20:00	
9	CHP	CC-51	MPD TRIPPED	RESET DONE	18:30:00	18:35:00	
10	CHP	CC-131	TRIPPED ON OLR	RESET DONE	18:40:00	18:45:00	
11	CHP	CC-113	CONTROL TRIPPING	PULL CORD AND BELT SWAY BYPASS ... FAULT ISOLATED	17:45:00	18:15:00	
12	CHP	CC-37 SCR-7	SLEW NOT WORKING	OIL TEMP HIGH ... OIL COOLER TRIPPED .. RESET DONE	21:45:00	22:00:00	
13	IOSA	L and T WBR	BW NOT WORKING	DOWN LIMIT ACTED ... RELEASED	17:30:00	17:50:00	