



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/05/2025

Shift: C

Incharge(s): Lal Singh

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|--|----------|----------|-------------------|
| 1 | OHP | co-29 | tripped on olr | reset done | 22:35:00 | 22:40:00 | |
| 2 | OHP | co-12 | nor running | zss cage ston stuck ... made free | 23:50:00 | 00:10:00 | |
| 3 | OHP | co35 | tripped on olr | reset done (3 times) due to deck sheet jamming | 00:10:00 | 00:15:00 | |
| 4 | OHP | vf-9 | not running | power was in off ... made on | 00:55:00 | 01:15:00 | |
| 5 | OHP | co-7 and co-5 | brs bypass request from operation | bypassed | 03:00:00 | 03:10:00 | |
| 6 | OHP | co-22 tbs | r-luff not working | olr acted ... reset done | 02:40:00 | 03:00:00 | |
| 7 | OHP | co-26 wobr | no drives working | control off due to down E LS.. luff up done by bypassing ... then tested | 04:10:00 | 04:25:00 | |
| 8 | CHP | cc-27a | flap gate tripped | reset done | 01:50:00 | 02:00:00 | |
| 9 | CHP | cc-54 | tripped on olr | rest done | 01:20:00 | 01:25:00 | |
| 10 | CHP | cc-131 | tripped on olr | reset done | 05:30:00 | 05:35:00 | |
| 11 | CHP | cc-32 scr-5 | bc stoped on dis chut sensor | bypassed | 23:50:00 | 00:15:00 | again kept in ckt |
| 12 | CHP | cc-36 scr-1 | luff not working | olr acted ... reset | 00:30:00 | 00:50:00 | |
| 13 | CHP | cc-35 scr-2 | pcrd cable stuck between drum and frame | cable adjusted | 02:15:00 | 03:15:00 | |
| 14 | CHP | op-9 | reverse not moving ... limit acted | released | 03:40:00 | 04:00:00 | |
| 15 | WT | ct-1 inhaul | mpcb tripped | made on | 22:30:00 | 22:40:00 | |
| 16 | WT | cp-1 | d-6 tripping ... lug cut | made off and bypassed in program | 23:40:00 | 00:15:00 | |
| 17 | WT | ot-1 | drive -1 tripping on pgf fault | reset done ...buffer problem ... informed mech | 02:00:00 | 04:30:00 | |



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/05/2025

Incharge(s): Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|----------------|------------|----------|----------|---------|
| 18 | IOSA | oc-25a | tripped on olr | reset done | 01:00:00 | 01:25:00 | |