



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 23/05/2025

Area: WT

Equipment	Job
OP 9	checked @ dead end found over traveled to non- power zone, brought it to power zone(striker to be adjusted)
CP 1	D6 ,35 sq mm cu lug(B-Phase) replaced in T B,power made ON and bypass removed
CP 1 and 3	after rake maintenance done
OP 2,4,6 and 8	after rake maintenance done