



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/02/2026

Area: WT

Equipment	Job
OP 10 jobs	Mast and D B Rs shifted to pusher and identified some of the cables
OP 5	Relay "VSPD1" replaced in parking zone panel, tested OK
OP 5	Parking zone area track lifting done by Railways, checked found OK
OP 2,4 and 6	After rake maintenance done