



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 16/07/2025

Incharge(s): V Balaji Naik

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO10A carriage	Drive MPCB was tripped	reset done	16:45:00	16:55:00	
2	OHP	TT4	Lt not moving found MPCB was tripped	Reset done	15:40:00	15:50:00	
3	OHP	Stacker on CO7A	No power ACB trip	Made on	15:50:00	16:15:00	
4	OHP	BRC on CO33M	BW1 not running stopping wrong complaint	Wrong complaint ZSS checked ok	21:10:00	21:30:00	
5	OHP	CO26	OLR acted	Reset done	18:05:00	18:15:00	
6	OHP	CO29	OLR acted	Reset done	19:50:00	20:00:00	
7	OHP	CO11A TIS	Motor terminals disconnected as per mechanical request	TIS bypassed again bypass removed and mechanical work also completed clearance given	21:40:00	21:50:00	No delay
8	CHP	CP1	No movement before starting rake found emergency not released by railways	Emergency released then ok	20:05:00	20:20:00	No electrical delay RLY delay
9	CHP	CC52	Over load acted 2 times	Reset done	15:15:00 19:20:00	15:20:00 19:25:00	feeding conveyor stopped
10	CHP	Cc131	Over load acted 2 times	reset done	19:50:00	19:55:00	8.10pm to 8.15pm
11	CHP	CC54	Over load acted 2 times	Reset done	17:25:00	17:30:00	7.35pm to 7.40pm



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/07/2025

Incharge(s): V Balaji Naik

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC51	not moving found ZSS acted due to jamming	Informed to operation jam cleared clearance given	17:10:00	17:15:00	
13	CHP	RG2	ZSS acted due to rotor jamming	Informed to house keeping team	18:00:00	18:05:00	
14	CHP	SCr10 on Cc105	BC not stopping and mode not changed from BC MPR tripped9 earth fault)	earth fault reset done and Machin interlock in CM 18 is in Reclaiming fuse removed then came to stacking mode clearance given	17:05:00	17:20:00	
15	CHP	CC125	OLR tripped	reset done	20:15:00	20:20:00	
16	WT	OT1	Reverse limit adjusted as per mechanical request	Adjusted	19:30:00	19:30:00	No delay no rake
17	WT	SCO1A carriage	OLR acted	reset done	21:10:00	21:15:00	