



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/02/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 1A ZSS	ZSS PROBE CHECK NUT LOOSE	TIGHTENED	18:40:00	18:55:00	
2	OHP	WBR ON CO 29 LT	ACB IS IN OFF CONDITION	MADE IT ON	14:50:00	15:00:00	
3	OHP	CO 26	OLR ACTED	RESET	16:00:00	21:10:00	5 TIMES
4	OHP	CO 29	PULL CORD BYPASSED	DUE TO CABLE CUT DURING JCB CLEANING	16:20:00	16:30:00	
5	OHP	BRC ON CO 31 LT	PCRD O/T ACTED	RESET	17:00:00	17:10:00	
6	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	16:20:00	20:50:00	
7	CHP	CC 58	OLR ACTED	RESET	21:25:00	21:40:00	
8	CHP	SCR 1 ON CC 34	POSITION SENSOR CHANGED	AND KEPT IN CIRCUIT	14:30:00	14:50:00	
9	CHP	CC 216	OLR ACTED	RESET	14:50:00	15:00:00	
10	CHP	CC 108	OLR ACTED	RESET	16:20:00 17:30:00	16:30:00 17:40:00	