



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/07/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------------|-------------------------------|---|----------------------|----------------------|---------|
| 1 | OHP | RECLAMIN G STREEM | ALL RED NEW LC-3 IC-2 TRIPPED | BC MADE ON | 16:40:00 | 16:55:00 | |
| 2 | OHP | CO-31 BRC | LT NOT WORKING | REMOTE SELECTION NOT THERE ... KEPT IN REMOTE AND TESTED | 19:00:00 | 19:25:00 | |
| 3 | OHP | CO-15 | TRIPPED ON OLR | RESET DONE | 17:00:00 21:10:00 | 17:15:00 21:20:00 | |
| 4 | CHP | cc-102 | BRS BYPASS REQ | BYPASSED | 14:30:00 | 14:40:00 | |
| 5 | CHP | CC-29 | TT CHUT SENSOR NOT HEALTHY | NO POWER IN TT ... POWER RESTORED THEN OK | 16:20:00 | 16:50:00 | |
| 6 | CHP | CC-20 | CHUT SENSOR NOT HEALTHY | CONTROL LOOSED IN PANEL ... FIXED PROPERLY | 17:10:00 | 17:20:00 | |
| 7 | CHP | CC-201 AND CC-203 | TRIPPED ON OLR | RESET DONE | 15:20:00 | 15:30:00 | |
| 8 | CHP | CC-125 | TRIPPED ON OLR | RESET DONE | 16:30:00 | 16:45:00 | |
| 9 | CHP | CC-32 SCR-5 | SLEW NOT WORKING | OIL LEVEL LOW ... ALARM RESET DONE | 17:20:00 | 18:00:00 | |
| 10 | CHP | CC-32 SCR-5 | BC NOT RUNNING | TRIPPED ON OLR ... RESET DONE | 18:15:00 | 18:30:00 | |
| 11 | CHP | CC-39 | YARD EMERGENCY PB DAMAGED | REPLACED | 17:20:00 | 17:35:00 | |
| 12 | CHP | CC-39 SCR-6 | BC NOT RUNNING | OLR ACTED ... RESET DONE | 20:10:00 | 20:20:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/07/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|---|-----------------------------------|----------|----------|---------|
| 13 | CHP | CC-40 SCR-3 | BC AND BW STOPPING ... BECAUSE OF SIGNAL MISSING | MACHINE LT DONE ... THEN OK | 19:45:00 | 20:00:00 | |
| 14 | CHP | CC-201 | TRIPPED ON OLR | RESET DONE | 20:45:00 | 21:00:00 | |
| 15 | WT | OT-4 | DRIVE TRIPPED IN PGF -4 FAULT | RESET DONE | 16:20:00 | 16:30:00 | |
| 16 | WT | CC-2 CD | TRIPPED ON OLR | RESET AFTER CLEANING | 16:15:00 | 16:50:00 | |
| 17 | IOSA | OC-13A | STOPPED ON ZSS | STONE STUCK IN CAGE ... MADE FREE | 20:50:00 | 21:05:00 | |
| 18 | IOSA | HVMCC-6 | IC-1 TRIPPED | CHECKED AND MADE ON | 21:10:00 | 21:20:00 | |