



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO7a	reported no drives running found ACB tripped	ACB made on	17:40:00	18:00:00	
2	OHP	CO32a	BRS kept in ckt	in ckt patch work done and mechanical dept requested	21:10:00	21:10:00	
3	CHP	CC 41	cjd acted, bypass cable loose in i/o rack	cable tightened than healthy	19:00:00	19:10:00	
4	CHP	CC 38 SCR 6	b/c not running, signal missing, for all conveyor	power recycle done in CCR micro plc	19:10:00	19:35:00	
5	CHP	CC 33 SCR4	LT not working	wrong complaint, informed operation	19:50:00	20:00:00	
6	CHP	CC51	over load tripped 2 times due to over load (feeding conveyor stopped)	Reset done	18:10:00	18:20:00	
7	CHP	CC114	over load tripped	Reset done	18:40:00	18:50:00	
8	WT	CC3 Belt	Over load Tripped	Reset done	17:25:00	17:30:00	
9	WT	SCO1A	R phase lug damaged	Replaced	17:30:00	17:30:00	No delay
10	WT	CT2 Inhaul	olr tripped	Reset done	18:30:00	18:40:00	