



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/09/2025

Incharge(s): Saurabh Kumar Yadav, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on co 26	slew not working drive tripped	reset	18:15:00	18:30:00	
2	OHP	VS 1A	olr acted	reset	16:25:00	16:30:00	
3	OHP	co 11(c)	tripped in overload	reset	17:00:00	17:10:00	
4	CHP	CC 40	Luff not working	Air lock problem , informed to mechanical	15:55:00	16:15:00	
5	CHP	CC 46	ZSS acted	holding nut tightened	17:50:00	18:00:00	
6	CHP	CC 126	Chute sensor acted	module problem , replaced	17:00:00	17:30:00	
7	CHP	CC 40 , S-1	Slew and hoist not working	slew 30 degree acted and luff up limit acted. Released limit, then ok	19:30:00 20:30:00	20:00:00 20:50:00	
8	CHP	CC 39 , SCR 3	BC not working	arch chute not fixed properly	20:10:00	20:30:00	