



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/06/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-6a	BRS NOT RESETTING	RECEIVER RETURN WIRE JOINT PROBLEM .. RECTIFIED	15:00:00	15:20:00	
2	OHP	CO-29	OLR ACTTING FREQUENTLY DUE TO DECKSHEET JAMMING	INFORMED OPERATION ... RESET DONE	18:00:00	21:00:00	
3	OHP	CR-3	LUBRICATION OIL FLOW SWITCH PROBLEM	OPENED AND CLEANED	18:30:00	19:00:00	
4	OHP	CO-48	TRIPPED ON OVER LOAD	RESET DONE	18:00:00	18:10:00	
5	OHP	CO-32 BRC	BW-2 STOPPING ON ZSS	T4 TIMER COIL REMOVED	21:30:00	22:00:00	
6	OHP	CO-27A	BRS KEPT IN CKT	DONE	20:30:00	20:35:00	
7	OHP	CO-21	BRS BYPASS REQUEST	BYPASSED	18:00:00	18:10:00	
8	CHP	CC-131	TRIPPED ON OLR	RESET DONE	19:25:00 20:20:00 21:30:00	19:30:00 20:25:00 21:35:00	
9	CHP	CC-51A	TRIPPED ON OVER LOAD	RESET DONE	14:45:00	14:50:00	
10	CHP	CC-53	TRIPPED ON OVER LOAD	RESET DONE	20:55:00	21:00:00	
11	CHP	CC-12	BRS BYPASSED DUE TO DUST ON OPERATION REQUEST	BYPASSED	15:30:00	15:35:00	
12	CHP	CC-32 SCR-5	LT NOT WORKING	M3 MPCB TRIPPED ... RESET DONE	16:00:00	16:32:00	
13	CHP	CC-104 SCR-10	SIGNAL PROBLEM	MACHINE LT DONE THEN OK	18:15:00	18:35:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/06/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-38 SCR-3	SLEW NOT WORKING (OPERATOR FAULT) BC IS RUNNING WHILE CHANGING BOOM POSITION FROM GVM TO OHP SIDDE	INFORMED OPERATOR	16:00:00	16:15:00	
15	CHP	CC-33 SCR-4	SLEW NOT WORKING (WRONG COMPLAINT)	TESTED FOUND OK	16:00:00	16:20:00	
16	CHP	CC-105 SCR-10	SLEW BW NOT WORKING	OIL LOW INFORMED MECH	21:25:00	21:45:00	
17	IOSA	IOSA TBS	LT LMIT ACTED DUE TO PLANTS	RESET	14:55:00	15:10:00	