



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/07/2025

Area: WT

Equipment	Job
MIS	CC 3 Ventilation, Coal and Ore Exhaust Fans kept ON in LC 9
OP 9	D5 (M2) New motor (LHP) placed on bed,alignment,termination and auto tuning done
CP 3	D 4 motor realignment done but due to gear box problem kept in bypass
CP 1 and OP 4	after rake maintenance done,CP 1 /D5 TB found loose ,tightening done