



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/11/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11 CD	OLR ACTED	RESET	00:05:00	00:15:00	
2	OHP	BRC ON CO 28 LT	CONTROL MCB TRIPPED	MADE IT ON THEN OK	22:50:00	23:00:00	
3	OHP	BRC ON CO 28 LT	CRMP SIDE MATERIAL JAMMING DRIVE TRIPPED	RESET	23:30:00	23:45:00	
4	OHP	CO 26	OLR ACTED	RESET	01:15:00 03:00:00 22:20:00	01:25:00 03:10:00 22:30:00	
5	OHP	TBS ON CO 5A	ACB TRIPPED	MADE IT ON	00:40:00	01:10:00	
6	OHP	WBR ON CO 26	SLEW DRIVE TRIPPED	RESET	02:15:00	02:30:00	
7	OHP	CO 29	OLR ACTED	RESET	03:50:00	04:00:00	
8	OHP	VF 1A	M1 MPCB TRIPPED DUE TO JAMMING	MADE IT ON	03:40:00	03:55:00	
9	CHP	CC 18	MCCB OUTGOING B PHASE FEMALE FINGER CONTACTOR MELTED	MALE CONTACTOR PROPERLY CLEANED AND SPARE MCCB MODULE RACKED IN AND TESTED	23:00:00	23:45:00	MALE FINGER CONTACTOR TO BE CHECKED
10	CHP	CO 19	MPD ACTING ON UNDER CURRENT	DISABLED	23:20:00	23:30:00	
11	CHP	CC 54	OLR ACTED	RESET	00:10:00	00:20:00	
12	CHP	CC 51	FEEDING CONVEYOR OLR ACTED	RESET	23:00:00	05:30:00	15 TIMES
13	CHP	CC 131	OLR ACTED	RESET	00:15:00	05:35:00	4 TIMES



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 31, 32, 33 RED	CM 22 TRIPPED	MADE IT ON	22:25:00	22:35:00	
15	CHP	CC 49 ZSS MODULE	SHIFTED NEAR MOTOR	KEPT IN CIRCUIT	22:30:00	23:00:00	NO DELAY
16	CHP	SCR 5 ON CC 33	LT DRIVE TRIPPED	RESET	00:05:00 00:40:00	00:15:00 01:00:00	
17	CHP	CC 45	OLR ACTING DUE TO TAIL END JAMMING	RESET AND INFOREMED TO OPRN	03:30:00	03:40:00	
18	WT	CT1	WAGON SENSOR ACTED	WAGON PLACED PROPERLY	00:00:00	00:10:00	
19	WT	OT5	DRIVE 2 TRIPPED ON SHORT CIRCUIT FAULT	RESET THEN RUN OK	01:00:00	01:10:00	
20	WT	AF4	DRIVE TRIPPED ON SPEED DEVIATION FAULT	RESET	05:15:00 05:35:00	05:20:00 05:40:00	