



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/01/2026

Incharge(s): Lal Singh,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co-28	24V FUSE BLOWING IN HYDRAULIC JB AND IN MCC	HIGH TO OIL LEVEL AND SECTION LINE REMOVED IN HYDRAULIC JB	22:00:00	23:30:00	
2	OHP	BRC ON CO-28	BW-1 NOT RUNNING	NO ELECTRICAL PROBLEM ... INFORMED MECH	04:01:00	04:25:00	
3	OHP	BRC ON CO-31	BW-1 OLR ACTED	RESET DONE	01:30:00	01:40:00	
4	OHP	CO-26	TRIPPED ON OLR	RESET DONE	05:50:00	06:00:00	
5	CHP	CC-51	TRIPPED ON OLR 3 TIMES	RESET DONE	00:25:00	01:53:00	
6	CHP	CC-51	MPD TRIPPED 2 TIMES	RESET DONE	03:00:00	05:30:00	