



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 02/02/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-1A	OLR ACTED (2TIMES)	RESET DONE	08:00:00	08:15:00	
2	CHP	CC-19	OLR ACTED	RESET DONE	10:10:00	10:15:00	
3	CHP	CC-58	OLR ACTED	RESET DONE	06:55:00	07:00:00	
4	CHP	CC-54	OLR ACTED	RESET DONE	08:55:00	09:00:00	
5	CHP	CC-131	OLR ACTED	RESET DONE	09:45:00	09:50:00	
6	CHP	CC-32 SCR-5	REPORTED SLEW NOT WORKING	WRONG COMPLAINT	08:15:00	08:20:00	
7	CHP	CC-37 SCR-3	REPORTED LUFF NOT WORKING FOUND OPERATOR CABIN CD STOP PB RETURN CORE PROBLEM	REPLACED WITH SPARE CORE THAN OK	12:00:00	12:20:00	
8	WT	OT-3	DRIVE-2 TRIPPED ON EARTH FAULT CHECKED AND FOUND MOTOR BURNT	G-SHIFT ATTENDED AND MOTOR REPLACED	09:00:00	09:10:00	