



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 6A	LT not working due to pcrd overtension	released	23:00:00	23:15:00	
2	OHP	BRC on CO 28	BC overload acted due to material jamming	reset done	03:30:00	04:00:00	
3	OHP	CO 84	OLR acted	reset done	04:00:00 05:30:00	04:05:00 05:35:00	
4	OHP	TBS on CO 23	Right luff OLR acted	reset done	04:30:00	04:50:00	
5	OHP	TBS on CO 20	Chute sensor acting without jamming	bypassed	04:30:00	04:45:00	
6	OHP	CO 87	OLR acted	reset done	01:30:00	01:40:00	
7	OHP	CO 26	OLR acted	reset done	05:30:00	05:40:00	
8	OHP	CO 30	BRS module problem	bypassed in module	22:00:00	23:00:00	
9	CHP	CC 35 , SCR 1	BC frequently stopped	checked , all ok. No electrical problem	00:00:00	00:30:00	
10	CHP	CC 104 , SCR 9	All drive not working due to incomer tripped	Found a 4 core cable near slew chamber one phase got opened. Then joint done properly , all drives checked	01:15:00	02:30:00	
11	CHP	CC 112 , S 3	LT not working	potentiometer zero , after increasing then healthy	03:15:00	03:30:00	
12	CHP	CC 51	MPD tripped	reset done	03:20:00 22:40:00	03:25:00 22:45:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 34	BRS to be bypassed as per operation and mechanical request	bypass done	04:55:00	05:00:00	in system
14	CHP	CC 15	Tripping in SPP fault	DPR bypassed	23:25:00	23:35:00	
15	WT	OT 5	D 1 and D2 tripped	made on	22:45:00	22:50:00	
16	WT	OT 1	D 1 tripped on PGF 1 fault	made on	03:15:00	03:20:00	