



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/08/2025

Shift: B

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO10A carriage	OLR acted due to over load	Reset done	19:45:00	20:05:00	
2	OHP	VS4A	Drive not healthy found nothing	Power recycling done	18:00:00	18:05:00	
3	CHP	CC26	Chute sensor acted due to jam	Reset done after jam clearance	14:25:00	14:35:00	
4	CHP	CC54	olr tripped	Reset done	17:30:00	17:35:00	08.30pm to 08.35pm and 08.50pm to 08.55pm
5	CHP	SCR4 on CC33	All drives not working found wrong complaint and LT reverse not working fount over travel limit acted	LT done in fwd direction then ok	14:30:00	14:45:00	
6	CHP	SCR9 on Cc104	pump running when slewing CMD given pump trip	Found high temperature warning signal informed to C shift	22:00:00	22:30:00	
7	WT	CO2 belt drive	MPCB tripped	Reset done	20:30:00	20:35:00	No delay
8	WT	CO3 belt drive	olr tripped 3 times due to over load	Reset done	17:00:00	17:00:00	