



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|----------------------------------|-------------------|----------|----------|---------|
| 1 | OHP | BF 1A | zss acted,probe disturbed | probe adjusted | 20:10:00 | 20:20:00 | |
| 2 | OHP | CO 20 | BRS acted,fuse blown in I/O rack | fuse replaced | 16:35:00 | 17:00:00 | |
| 3 | OHP | co 32 | BRS acted,belt piece found | reset | 18:25:00 | 18:30:00 | |
| 4 | CHP | CC 105 scr 10 | LT not working,PCRD OT acted | Ot released | 16:25:00 | 16:35:00 | |
| 5 | CHP | CC 34 SCR1 | LT not working,drive tripped | reset | 16:55:00 | 17:10:00 | |
| 6 | CHP | CC 203 | motor trip | reset | 17:45:00 | 17:55:00 | |
| 7 | CHP | CC 31 scr 4 | pcrd cable zigzag | properly rewinded | 18:25:00 | 19:00:00 | |
| 8 | CHP | CC 110 | BRS acted, | sensor cleaned | 18:10:00 | 18:20:00 | |