



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/05/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-35	TRIPPED ON OVER LOAD	RESET DONE	07:55:00	08:00:00	
2	OHP	CO-27A	BRS BYPASS REQUEST	BYPASSED IN MODULE	10:00:00	10:10:00	
3	OHP	TIS ON CO-25	TIS FAIL TO START FAULT	FEEDBACK COMING LATE ... RELAY MADE FREE	09:50:00 13:20:00	10:00:00 13:30:00	INFORMED G SHIFT
4	OHP	CO-28 BRC	BC NOT STARTING	EMERGENCY PB ACTED ... RELEASED	09:50:00	10:10:00	
5	OHP	CO-35	TRIPPED ON OVER LOAD	RESET DONE	10:35:00	10:45:00	
6	CHP	CC-33 S-1	LT NOT WORKING	DRIVE TRIPPED ON OVER LOAD ... RESET DONE	08:25:00	08:40:00	
7	CHP	CC-107	TRIPPED ON OVER LOAD	RESET DONE	10:30:00	10:35:00	
8	CHP	CC-52	STOPPED ON ZSS AND NOT STARTING	KEPT IN DOL AND AFTER LOAD CLEARING KEPT IN DERIVE AGAIN	11:00:00	11:10:00	
9	CHP	CC-114	TRIPPED ON OLR	RESET DONE	09:25:00	09:35:00	
10	CHP	CC-112 SCR-8	SLEW NOT WORKING	BREAK PRESSER SWITCH PROBLEM.... RECTIFIED BY INSTRUMENTATION	11:15:00	12:15:00	
11	CHP	cc-34 scr-2	luff not working	down limit acted ... released	13:00:00	13:30:00	