



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/07/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR acted ( 4 times)	reset done	06:40:00	11:45:00	
2	OHP	CO 35	OLR acted	reset done	07:25:00	07:30:00	
3	OHP	CO 29	Pull chord	kept in circuit	10:00:00	10:30:00	
4	OHP	CO 26	OLR acted	reset done	13:25:00	13:35:00	
5	OHP	CO 76R	Chute sensor acting without material	Bypassed	09:00:00	13:40:00	kept in circuit after instrumentation clearance
6	OHP	CO 17	Pull chord	kept in circuit	12:00:00	12:10:00	
7	CHP	CC 54	OLR acted	reset done	08:40:00	08:45:00	
8	CHP	CC 51	Tripped on overload	reset done	13:00:00	13:10:00	
9	CHP	CC 117	ZSS acted	Checked , belt snap. Informed to mechanical	10:20:00	10:25:00	
10	CHP	CC 104 , SCR 9	BC signal missing	LT done	07:15:00	07:30:00	
11	CHP	CC 48	BRS to be bypassed as per operation request	bypassed	09:45:00	10:00:00	in system
12	CHP	CC 104 , SCR 9	LT not working due to overtension acted	tension released	11:20:00	11:30:00	
13	CHP	CC 24	Carriage drive one phase missing	Spare core used	10:30:00	10:50:00	
14	CHP	CC 27	BRS bypass request by operation	Bypassed	09:45:00	09:50:00	in system
15	CHP	CC 24	Carriage drive tripped	made on	09:00:00	09:05:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	OC 1A	ZSS cage tilted	Cage replaced	06:39:00	07:00:00	
17	WT	OT 2	D -1 tripped on PGF fault	reset done	10:15:00	10:25:00	
18	WT	OT 5	Hopper lighting not there	MCB tripped , made on	11:00:00	11:15:00	
19	WT	SCO 1A	Carriage drive tripped on overload	reset done	11:20:00	11:30:00	
20	WT	OP 1	D 4 tripped	reset done	12:35:00	12:45:00	
21	WT	EOT crane ore	Power MCCB tripped	made on	13:00:00	13:15:00	
22	WT	OP 9	Communication problem	Move forward , then ok	10:50:00	11:00:00	
23	WT	SCO 1A	Belt drive overload	reset done	13:35:00	13:45:00	
24	WT	OT 5	LS 1 acted	Bypassed in system	13:30:00	13:35:00	