



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/12/2025

Area: CHP

Equipment	Job
LC 13	IO rack maintenance was done and communication issue resolved after replacing patch card
CC 54	PPM was done
CC 49	Motor vibration readings noted after decoupling
LC 4 PDB supply	Diverted cable from I/C 1 to I/C 2 side feeder
SCR 4,9	6nos 30W and 2no 70W fixtures provided
CC 43	Motor greasing done
CC 27,27A,103,CC 31,SCR 4	PPM was done