



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/07/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-35	TRIPPED ON OLR	RESET DONE	19:55:00	20:00:00	
2	OHP	CO-22 TBS	LT NOT WORKING	DRIVE TRIPPED ... RESET DONE	19:55:00	20:10:00	
3	OHP	CO-13 BD	TRIPPED ON OLR	RESET DONE	17:00:00	17:10:00	
4	OHP	CO-76R	CHUT SENSOR MALFUNCTIONING COMPLAINT	SENSOR ADJUSTED	15:30:00	15:45:00	
5	OHP	CO-21 TBS	CHUT SENSOR ACTING WHILE DOING LT	GAP ADJUSTED (TIED WITH ROPE)	19:55:00	20:10:00	
6	OHP	CO-20 TBS	L-LUFF NOT WORKING	BREAK PROBLEM INFORMED OPERATION	16:20:00	16:35:00	
7	OHP	CO-26 WBR	SLEW NOT WORKING	DRIVE TRIPPED RESET DONE	15:20:00	15:40:00	
8	OHP	CO-26 WBR	LUFF LOWER LIMIT BYPASS REQ FROM OPR	BYPASSED	16:00:00	16:30:00	
9	CHP	CC-51A	TRIPPED ON OLR	RESET DONE	20:55:00	21:00:00	
10	CHP	CC-53	TRIPPED ON OLR DUE TO JAMMING	RESET DONE AFTER CLEANING	19:30:00	21:30:00	
11	CHP	CC-131	TRIPPED ON OVER LOAD (FOUR TIMES)	RESET DONE	17:25:00	21:05:00	
12	CHP	CC-112 SCR-8	SIGNAL MISSING	LT DONE TOWARDS DRIVE END SIDE	16:40:00	16:55:00	
13	CHP	CC-40 SCR-6	BC STOPPING IN BETWEEN	ZSS CAGE STUCK ... REPLACED	17:20:00	17:45:00	
14	CHP	CC-40 SCR-6	BC STOPPING	CHECKED AND FOUND MATERIAL SELECTION MISSING INFORMED OPERATION	18:55:00	19:15:00	
15	WT	CO-2 BD	TRIPPED ON OLR	RESET DONE	21:55:00	22:00:00	