



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 20/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	15:45:00 17:15:00 17:50:00 21:10:00	15:55:00 17:25:00 18:00:00 21:15:00	
2	OHP	CO-26	TRIPPED ON OLR	RESET DONE	18:35:00 21:15:00	18:45:00 21:20:00	
3	OHP	RSCO-10A CD	TRIPPED ON OLR	RESET DONE	19:20:00	19:30:00	
4	OHP	CO-33A TO CO35A CHUT VIBRATOR	NOT WORKING	CHECKED AND FOUND IT IS SUBMERGED IN MATERIAL .. INFORMED OPERATION	17:50:00	18:05:00	
5	OHP	1-141 LC3	INCOMER -1 TRIPPED	MADE ON	21:00:00	21:10:00	
6	OHP	CO 28 BRC	LT NOT MOVING	BREAK WIRE OPEN ... CONNECTED	16:00:00	16:20:00	
7	OHP	CO-32 BRC	LT COMING BACK	CRMP SIDE BREAK NOT WORKING ... CONNECTIONS REMOVED IN G SHIFT BECAUSE OF CABLE PROBLEM	20:00:00	20:20:00	
8	CHP	CC-38 SCR-6	SLEW NOT WORKING	JAMMING ... INFORMED OPERATION	15:45:00	16:00:00	
9	CHP	CC-201	TRIPPED ON OLR	RESET DONE	16:45:00	17:00:00	
10	CHP	CC-203	NOT HEALTHY	PULL CORD ACTED ... RELEASED	16:45:00	17:00:00	
11	CHP	CC-107	TRIPPED ON OLR	RESET DONE	20:35:00	20:40:00	
12	CHP	CC-54	TRIPPED ON OLR (5 TIMES)	RESET DONE	17:30:00	20:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-25 TO CC-37	POSITION SIGNAL	FOUND OK .. SLECTION WRONG IN CCR ... INFORMED OPERATOR	14:30:00	14:45:00	
14	CHP	CC-26 FG	TRIPPED	Y PHASE PROBLEM ... CONNECTED PROPERLY	14:45:00	14:55:00	
15	WT	OT-3	D-1 TRIPPED	RESET DONE	20:25:00	20:30:00	
16	IOSA	OC-18A	CJD ACTED	HEALTHY AFTER CLEANING PROB	15:45:00	15:55:00	