



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/11/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

| Sl No | Area | Equipment     | Problem              | Action          | From                 | To                   | Remarks |
|-------|------|---------------|----------------------|-----------------|----------------------|----------------------|---------|
| 1     | OHP  | RSCO-9A       | TRIPPED ON OLR       | RESET DONE      | 10:03:00             | 10:15:00             |         |
| 2     | OHP  | BRC ON CO-30` | BC TRIPPED           | RESET DONE      | 09:20:00             | 09:30:00             |         |
| 3     | OHP  | co-23 tbs     | no power             | 3 ht fuse blown | 13:45:00             | 14:00:00             |         |
| 4     | CHP  | CC-45         | TRIPPED ON OLR       | RESET DONE      | 09:53:00<br>10:30:00 | 10:00:00<br>10:35:00 |         |
| 5     | CHP  | CC-51         | MPD TRIPPED 14 TIMES | RESET DONE      | 07:09:00             | 13:11:00             |         |
| 6     | CHP  | CC-54         | TRIP 16 TIMES        | RESET DONE      | 08:35:00             | 12:56:00             |         |
| 7     | CHP  | CC-117        | TRIPPED ON OLR       | RESET DONE      | 08:17:00             | 08:25:00             |         |
| 8     | WT   | PC-8          | REV L/S ACTED        | RELEASED        | 10:45:00             | 10:55:00             |         |