



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/11/2025

Area: CHP

Equipment	Job
CC 28	Emergency PB replaced
JH C 6, CC 109	Hoist panels maintenance was done
LC 17,18	Rooms cleaning done
CC 41/42	LDB incoming MCB and damaged SP MCBs replaced and improved lighting
SCR 1	LT end limit striker welded and tested
CC 34,SCR 2, 111,S3, 112,SCR 8	PPM was done
SCR 8	Stacking angle limits adjusted