



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 13/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment     | Problem  | Action                                 | From     | To       | Remarks                   |
|-------|------|---------------|--|--|----------|----------|---------------------------|
| 1     | OHP  | CO 37A        | STOPPING ON ZS CAGE STUCK UP   | ZS CAGE REPLACED                       | 09:30:00 | 09:45:00 |                           |
| 2     | OHP  | TBS ON CO 21  | LEFT B/C STOPPING ON ZS PROBE DAMAGED  | ZS PROBE REPLACED                      | 10:30:00 | 10:45:00 |                           |
| 3     | OHP  | CO 84         | OLR ACTED  | RESET                                  | 08:40:00 | 08:50:00 |                           |
| 4     | OHP  | BRC ON CO 34  | B/W S NOT RUNNING CP 1 TRIP  | RESET                                  | 12:10:00 | 12:30:00 |                           |
| 5     | CHP  | cc 32 scr 5   | B/C STOP in ZSS,cage problem   | ZSS cage replaced                      | 07:20:00 | 07:30:00 |                           |
| 6     | CHP  | CC 38 SCR3    | b/c stop in ZSS,cage and module problem  | ZSS cage and module replaced           | 08:00:00 | 08:15:00 |                           |
| 7     | CHP  | CC 105 SCR 10 | b/c not running,zss acted,coal stucked in ZSS cage,machine at tail end and scr 9 inbetween CCR | zss cage made free and LT done than ok | 10:55:00 | 11:10:00 |                           |
| 8     | CHP  | CC 105 SCR 10 | B/C not running,control mcb trip   | control mcb made on                    | 11:35:00 | 11:50:00 |                           |
| 9     | CHP  | CC 114        | OLR ACTED  | RESET                                  | 07:30:00 | 07:40:00 | DUE TO MATERIAL OVER LOAD |
| 10    | CHP  | CC 131        | OLR ACTED(3TIMES)  | RESET                                  | 08:10:00 | 08:15:00 |                           |
| 11    | CHP  | CC 54         | OLR ACTED(2TIMES)  | RESET                                  | 08:10:00 | 08:30:00 |                           |
| 12    | CHP  | CC 58         | OLR ACTED  | RESET                                  | 08:50:00 | 09:10:00 |                           |
| 13    | CHP  | cc 112        | D/E CJS not healthy probe touched body   | probe adjusted                         | 12:55:00 | 13:10:00 |                           |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment   | Problem                       | Action               | From     | To       | Remarks |
|-------|------|-------------|-------------------------------|----------------------|----------|----------|---------|
| 14    | CHP  | CC 18       | cjs acted,                    | sensor cleaning done | 07:00:00 | 07:10:00 |         |
| 15    | CHP  | CC 25       | mech BRS acted                | informed mech        | 07:30:00 | 07:45:00 |         |
| 16    | CHP  | CC 34 SCR 2 | LT not working, PCRD OT acted | OT released          | 13:10:00 | 13:20:00 |         |