



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/07/2025

Area: IOSA

Equipment	Job
OC-19A	PPM DONE ON PANEL AND MOTOR OF OC-19A H/E and T/E DE-WATERING PUMPS.
OC-21A	PPM DONE ON MOTOR . SPARE MOTOR ALSO CLEANED.
OC-2A , OC-3A	FIELD DEVICES FEEDBACK CHECKING DONE.
OC-7B	LIGHTING DB , WELDING SOCKETS AIR BLOWING DONE.
WOBR (FLS)	SLEW and BUCKET WHEEL HYDRAULIC SOLENOID PLUG, LEVEL SENSOR AND TEMPERATURE RTD REMOVED AS MECHANICAL CLEANING THE OIL TANK AND FILLING OIL. FIXED BACK AND TRIAL RUN TAKEN.
OC-36A	MOTOR ONE SIDE EARTHING GOT RUSTED AND CUT. REPLACED WITH NEW CABLE.