



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/10/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED(2TIMES)	RESET DONE	09:00:00 11:30:00	09:10:00 11:40:00	
2	OHP	CO-26	OLR ACTED	RESET DONE	09:45:00	09:55:00	
3	OHP	VS-2	OLR ACTED(2TIMES)	RESET DONE	07:50:00 09:45:00	08:00:00 09:55:00	
4	OHP	VS-1	OLR ACTED	RESET DONE	10:00:00	10:10:00	
5	OHP	TT-2 F/G	MPCB TRIP	RESET DONE	10:20:00	10:30:00	
6	OHP	TT-4 ON CO-3A	LT NOT TAKING PLACE MPCB TRIP DUE TO TRACK JAMMING	MPCB MADE ON THAN OK	10:30:00	10:40:00	
7	OHP	TT-2 ON CO-15	TT C/S INDICATION MISSING CHECKED AND FOUND OLD JOINT OPEN IN PCRD DRUM C/S BYPASSED	CABLE JOINT DONE AND C/S KEPT IN CIRCUIT	12:30:00	13:15:00	
8	OHP	BRC ON CO-32	YARD INTERLOCK INDICATION MISSING	ZSS MODULE WIRES TIGHT THAN OK	10:45:00	10:55:00	
9	OHP	CC-43	MPD OLR ACTED	RESET DONE	10:00:00	10:10:00	
10	CHP	CC-51	OLR ACTED (21TIMES) FEEDING CONVEYOR STOP	RESET DONE	08:00:00	13:30:00	
11	CHP	CC-54	OLR ACTED (4TIMES)	RESET DONE	08:00:00	08:25:00	
12	CHP	VF-3	DRIVE TRIP	RESET DONE	07:40:00	07:55:00	
13	CHP	CC-31 SCR-4	REPORTED PCRD CABLE FELL DOWN	PCRD CABLE PROPER WINDING WAS DONE THAN OK	07:00:00	07:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/10/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-38 SCR-6	LT NOT TAKING PLACE FOUND DRIVE TRIP DUE TO TRACK JAMMING	DRIVE RESET DONE	07:30:00	07:45:00	
15	CHP	CC-31 SCR-4	REPORTED B/W STOPPING CHECKED AND FOUND COAL JAMMING	INFORMED TO OPERATION	07:50:00	08:00:00	
16	WT	OP-8	REPORTED NOT MOVE FOUND SIGNAL PROBLEM	PLC POWER RE-CYCLED THAN OK	13:00:00	13:30:00	
17	WT	OP-10	NOT MOVE CHECKED AND FOUND COL NO-22 TO COL NO-38 TRACK PROBLEM	ALL THINGS CHECKED NO ELECTRICAL PROBLEM	08:00:00	13:00:00	