



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/04/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC 31	b/c not running,olr acted	reset	17:44:00	18:00:00	
2	OHP	TBS on 20	R/bc not moving,olr acted	reset it done	18:15:00	18:30:00	
3	OHP	TBS on 22	c/s not working,	probe cleaned	15:10:00	15:30:00	
4	OHP	WOBR 25	slewing not working,hydraulic pipe damaged	informed mech	20:25:00	20:30:00	
5	OHP	WOBR 26	slewing not working,drive trip in olr	reset	21:30:00	21:45:00	
6	CHP	CC 32 scr 5	B/c not running,trips in unbalance fault,jamming was there	reset ,and opertaion cleaned	14:40:00	15:00:00	
7	CHP	CC 34 scr 2	LT not taking place,OT acted,mech problem guide rolller	ot released,informed mech	17:12:00	17:20:00	
8	CHP	CC 34 scr 2	gvl side plc bit not high	bypass in i/o rack	18:00:00	18:10:00	
9	CHP	CC 34 SCR2	b/c stopping,	checked all interlock all ok	21:00:00	21:10:00	20 min checked b/c not stopped
10	WT	OP 1	NOT MOVING ACB TRIPPED IN LC 2A	MADE ON	14:00:00	14:20:00	
11	WT	CP 1	NOT MOVING F/W LIMIT ACTED	RESET	14:00:00	14:15:00	
12	WT	OP 9	NOT MOVING C CLAMP DAMAGED JUMPER GOT CUT	C CLAMP AND JUMPER REPLACED CABLE LUG CHANGED	14:30:00	15:00:00	
13	WT	oP 5	NOT MOVING,EMERGENCY NOT RELEASED BY RAILWAY	EMERGENCY RELEASED	19:00:00	19:15:00	operation delay
14	WT	OP 10	Not moving,emergency not released by railway	emergency released	21:00:00	21:10:00	