



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/07/2025

Shift: C

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 22	L/BOOM NOT RUNNING OLR ACTED	RESET	22:30:00	22:45:00	
2	OHP	CO 29	OLR ACTED (5TIMES)	RESET	23:00:00	04:00:00	
3	OHP	CO 26	OLR ACTED	RESET	03:40:00	03:45:00	
4	OHP	CO 17	PC ACTED	PULL CHORD BY PASS OPERATION REQUIREMENT	04:30:00	04:45:00	
5	OHP	CO 5	FAIL TO START INTER PHASE AUX RELAY PROBLEM	SPARE RELAY REPLACED THAN OK	03:30:00	04:30:00	
6	OHP	TBS ON CO 7A	L/LUFF DRIVE TRIP	RESET	05:20:00	05:40:00	
7	CHP	CC 17	OLR ACTED	RESET	05:05:00	05:10:00	
8	CHP	CC 31 F/G	OLR ACTED	RESET	02:30:00	02:40:00	
9	CHP	CC 117	OLR ACTED	RESET	05:20:00	05:46:00	
10	CHP	CC 31 R1	B/C NOT RUNNING BELT OFF CENTERING	IN FORMED TO MECH	23:45:00	00:00:00	
11	CHP	CC 34 SCR 2	LT NOT TAKING PLACE O/T ACTED	RELEASED	00:05:00	00:15:00	
12	CHP	CC 32 SCR 5	SLEW NOT WORKING	FAULT RESET THAN OK	00:20:00	00:35:00	
13	CHP	CC 39 S1	B/C NOT RUNNING SIGNAL PROBLEM	LT MOVE FWD THAN OK	01:30:00	01:40:00	
14	CHP	CC 201	OLR ACTED	RESET	01:30:00	01:40:00	
15	CHP	CC 32 SCR 5	SLEW NOT TAKING PLACE 30 LIMIT ACTED	INFORMED TO OPERATION	02:10:00	02:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/07/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 203	OLR ACTED	RESET	02:30:00	02:40:00	
17	CHP	CC 31 R1	B/C STOPPING ON ZS CAGE STUCK UP	ZS CAGE RELEASE	00:30:00	00:40:00	
18	CHP	CC 32 SCR 5	B/C OLR TRIP	RESET	03:10:00	03:30:00	
19	CHP	CC 104 SCR 9	BC NOT RUNNING SIGNAL PROBLEM	LT MOVE FWD THAN OK	03:20:00	03:30:00	
20	CHP	CC 40 SCR 6	B/C NOT RUNNING CHUTE JAMMING	INFORMED TO OPERATION	04:40:00	04:50:00	
21	CHP	CC 104 SCR 9	MPR TRIP DUE TO B/C NOT RUNNING	RESET	05:20:00	05:30:00	