



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-78	REPORTED E/STOP ACTED FOUND GLASS FUSE BLOWN IN CJB	FUSE REPLACED THAN OK	08:25:00	08:50:00	
2	OHP	TBS ON CO-7A	LT NOT TAKING PLACE DRIVE TRIP	RESET DONE	13:10:00	13:25:00	
3	CHP	CC-28	TRIPPED ON OLR	RESET DONE	11:55:00	12:05:00	
4	CHP	CC-117	OLR ACTED	RESET DONE	10:30:00	10:50:00	
5	CHP	CC-51	MPD TRIP (20TIMES) FEEDING CONVEYOR STOP	RESET DONE	06:30:00	13:50:00	
6	CHP	CC-54	OLR ACTED (4TIMES)	RESET DONE	07:30:00	10:00:00	
7	CHP	CC-32 R-1	REPORTED B/C NOT RUNNING FOUND ZSS CAGE STUCK UP WITH COAL MATERIAL (3TIMES)	COAL REMOVED THAN OK	07:50:00 11:50:00 13:00:00	08:00:00 12:00:00 13:10:00	
8	CHP	CC-38 SCR-6	LT NOT TAKING PLACE M-1,M-2 MPCB TRIP DUE TO TRACK JAMMING	RESET DONE AND INFORMED TO OPERATION	08:10:00	08:20:00	
9	CHP	CC-45	TRIPPED ON OLR (4TIMES)	RESET DONE	09:30:00	12:20:00	
10	CHP	CC-37 SCR-7	B/C NOT RUNNING MPR TRIP	RESET DONE	13:10:00	13:25:00	
11	WT	OT-3	REPORTED NOT MOVE FOUND DRIVE-1 TRIP ENCODER FAULT	RESET DONE	07:20:00	07:30:00	
12	WT	CO-2 (BELT DRIVE)	REPORTED STOPPING ON ZSS FOUND ZSS CAGE WHEEL STUCK UP	ZSS CAGE REPLACED WITH NEW THAN OK	12:10:00	12:40:00	